



Project Name: Bennett's Creek

DAI Project Number: 26032

8/12/2026

This Addendum becomes fully a part of the previously issued Quote Package as if originally issued therewith or originally contained therein.

The Addendum includes additions to, deductions from, changes and substitutions in, or clarifications and emphasis on parts or requirements of the drawings and specifications pertaining to the project.

Contractors shall familiarize themselves with Addendum items and they shall be held responsible for complete knowledge of same.

E2.1 – Lighting Plan South Wing

- Site lighting plan revised to match civil drawings, sconces eliminated
- Note about life safety UL 924 devices added

E2.2 – Lighting Plan Center

- Site lighting plan revised to match civil drawings, downlights eliminated, sconces added
- Exterior egress lighting added at back and side doors
- Lighting control schedule revised to match
- Note about life safety UL 924 devices added

E2.3 – Lighting Plan North Wing

- Site lighting plan revised to match civil drawings, sconces eliminated
- Note about life safety UL 924 devices added

E2.4 – Site Lighting Plan

- Site lighting plan revised to match civil drawings
- Low voltage sign lighting eliminated, sign lighting to be determined in the future

E6.1 – Lighting Fixture Schedule

- Fixture RH added, to be used as exterior egress lighting, only on during normal power outages, powered by life safety circuit