

PANEL - A																											
TYPE		BOLT-ON		MOUNTING				FLUSH				ENCLOSURE				NEMA-1				PHASE 3				WIRE 4			
VOLTS		120/208		MAIN				400A MLO				FRAME				400A				SHORT CIR.RATING				22,000 RMS SYM MIN			
CKT. NO.	CKT. TRIP	DESCRIPTION	PHASE		LOADING		A		B		C		LOADING		PHASE		DESCRIPTION	A		B		CKT. NO.	CKT. TRIP				
			A	B	A	B	A	B	A	B	A	B	A	B	A	B											
1	50/2	HP-1		28		28								4		12	RCPT - PORCH 9					20/1	2				
2																	RCPT - CONF 2					20/1	4				
3	90/2	AHU-1					70									6	FIREPLACE - LOBBY 1A					20/1	6				
7							70							14			RCPT - OFF. 15					20/1	8				
9	25/2	HP-3													12		RCPT - COPIER 13					20/1	10				
11																10	RCPT - LOBBY 1A					20/1	12				
13	40/2	AHU-3				30								14			RCPT - OFFICE 3					20/1	14				
15							30								10		RCPT - MEN 6					20/1	16				
17	20/2	HP-2									15					10	RCPT - CORR 87					20/1	18				
19														10			RCPT - CONF 9					20/1	20				
21	30/2	AHU-2				21									12		RCPT - PORCH 92					20/1	22				
23							21										RCPT - CONF 9					20/1	24				
25	20/2	HP-8				15								6			FIREPLACE IV - 37					20/1	26				
27							15								8		RCPT - DUNCAN 37					20/1	28				
29	30/2	AHU-8									21					-	SPARE					20/1	30				
31							21															20/1	32				
33	25/2	HP-4													30		AHU-28					40/2	34				
35																30							36				
37	20/1	RCPT - CHAPEL 85				12								97			PANEL AA					150/3	38				
39	40/2	AHU-4					30								89								40				
41																104							42				
SUBTOTAL						191	156		189					145	173	164								X			
			TOTAL PANEL LOAD:			AP 336A			BP 329A			CP 355A												NEUTRAL TERMINAL BAR			X
																								GROUND TERMINAL BAR			X
NOTES:																											