



Project Name: Home 2 Suites Greenwood SC
Project Location: 475 Hospitality Blvd, Greenwood SC 29649
Project Number: 23112

Re: Revision C – Power Coordination

These revised drawings form a part of the Construction Documents and modify the original Construction Documents dated Oct. 16, 2024 as noted below.

Listed below are the drawings that have been revised:

E002

1. Revised switchboard to be 2500A from 4000A.
2. Revised feeder sizes from 10 sets of 700 MCM to 6 sets.

E003

1. Added demand load calculation.
2. Revised switchboard to be 2500A from 4000A.
3. Added demand load for switchboard.

E700

1. Revised feeder size for switchboard.

Regards,

Hugh P. Bunn