

From: Miles Campbell <milescampbell@johnmcampbellcompany.com>
Sent: Tuesday, April 12, 2022 3:11 PM
Subject: John M Campbell Company
Fw: Embassy at Morehead City - RFI 2 Aluminum Door in HM Frame?

From: Wesley Runion
Sent: Tuesday, April 12, 2022 2:25 PM
To: Miles Campbell ; Kevin See
Cc: Alisha Morgan
Subject: RE: Embassy at Morehead City - RFI 2 Aluminum Door in HM Frame?

Hello Miles,

Please see the RFI#2 response below.

RFI #2 - A9.1 Door Schedule Clarification is now in Runion, Wes (Grand Contracting)'s court.

RFI Details

This RFI is due on Friday, April 15, 2022.

QUESTION 1

Asked By: Wes Runion (Grand Contracting)

Date: Tue Apr 12, 2022 at 09:29 am EDT

Question: A9.1 Door Schedule indicated listed openings to have aluminum and glass (A&G) door in a HM frame. Advise if this is correct. Typically these openings would be either aluminum door in aluminum frame or hollow metal door in hollow metal frame. May be warranty issue. A & G Door in HM Frame: 112C-200C-304-421-428A-C201-C300-C404.

Attachments: None

All Replies

Answered By: David Glenn (Architectural Concepts, Inc)

Date: Tue Apr 12, 2022 at 02:07 pm EDT

Response: All of the above mentioned doors (112C, 200C, 304, 421, 428A, C201, C300 and C404) should have Aluminum frames In lieu of HM frames.

Attachments: None

ADDITIONAL DETAILS

Project: Embassy at Morehead

Subject: A9.1 Door Schedule Clarification

Date Initiated: 04/12/22

Created By: Wes Runion (Grand Contracting)

Assigned To: Russ, Bo (Architectural Concepts, Inc)
Glenn, David (Architectural Concepts, Inc)

Thank you,

Wesley Runion | PMP | Project Manager

Grand Contracting | 802 East 86th Street | Indianapolis, IN 46240

wrunion@grandcontracting.net

C: 317-619-0014

O: 317-552-2295