



2246 Yaupon Drive  
 Wilmington, NC 28401  
 (910) 791-4000  
 Fax (910) 791-5266

# RFI Transmittal

CBHF Engineers | 2246 Yaupon Drive Wilmington NC 28401 United States

PROJECT: Pruitt Health Winston-Salem 23008 DATE SENT: 8/11/2023  
 SUBJECT: PB-RFI #004 Building side pumps RFI ID: PB-RFI #004  
 TYPE: RFI TRANSMITTAL ID: 00018  
 PURPOSE: Answered VIA: Email

QUESTION:  
 SUGGESTION:

ANSWER:

**Response (Answered) from: James Benson**

Remarks:

These pumps are furnished by Plumbing Contractor. Pump Schedule includes Heat-Timer PLL lead-lag controller, no additional controls are necessary. General operation is 24-7.

FROM

NAME	COMPANY	EMAIL	PHONE
CBHF CA	CBHF Engineers	CA@cbhfenegineers.com	910-791-4000

TO

NAME	COMPANY	EMAIL	PHONE
Dave Polston	David Polston, AIA	polstonaia@bellsouth.net	(910) 350-8900
Miles Campbell	John M. Campbell Company	milescampbell@johnmcampbellcompany.com	704.283.8191

DESCRIPTION OF CONTENTS

QTY	DATED	TITLE	NUMBER	SCALE	SIZE
1	8/10/2023	Pruitt Healthcare RFI 4.docx			

COPIES:

Eric Cassidy

(Brady Trane)



2025 16<sup>th</sup> Street Greensboro, NC 27405  
P: (336) 378-0670

**RFI – Request For Information**

**No. 004**

From: Brady Trane

Date: August 14, 2023

Job Name: Pruitt Health

Job Number: \_\_\_\_\_

Phone: 910-791-400 Fax: \_\_\_\_\_

To: CBHF Engineers, PLLC  
2246 Yaupon Drive  
Wilmington, NC 28401

RFI Title: Building side pumps

Description of Information Requested:

What is the sequence for pumps CWP-1, 2? Standalone operation 24/7?

Response:

These pumps are furnished by Plumbing Contractor. Pump Schedule includes Heat-Timer PLL lead-lag controller, no additional controls are necessary. General operation is 24-7.

By:	Jim Benson, PE; CBHF Engineers	By:	Robert Kantlehner /Brady Trane Controls
Date:	08/11/23	Date:	6/30/20

**Your Comfort. Our Promise.**